STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	15G461	A. BUILDING 01 B. WING _____	R 09/07/2011

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
DEVELOPMENTAL SERVICES INC	631 N ELM ST SEYMOUR, IN 47274

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the PSR conducted on 07/07/11 to the Life Safety Code Recertification Survey conducted on 05/20/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j). Survey Date: 09/07/11 Facility Number: 000975 Provider Number: 15G461 AIM Number: 100244820 Surveyor: Mark Bugni, Life Safety Code Specialist At this PSR survey, Developmental Services Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies. This one story facility was fully sprinklered with the exception of the fourteen foot by fourteen foot sun porch. The facility has a fire alarm system with smoke detection in the corridors, client sleeping rooms and common living areas. The facility has a capacity of 8 and had a census of 8 at the time of this survey. Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-score of 0.9.	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	15G461	A. BUILDING 01 B. WING _____	R 09/07/2011

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
DEVELOPMENTAL SERVICES INC	631 N ELM ST SEYMOUR, IN 47274

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 09/08/11.	{K 000}		